


794
23/11/15
SDM

1382
23/11/15
2/15PM

	BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED (Wholly owned by Government of Karnataka Undertaking)
Fax No.080-22342128, E-Mail:gmqs.work@gmail.com No: BESCOM/BC-35/GM(Q,S&S)/DGM-2/AGM-3/2015-16/	O/o the GM (Q,S&S), Corporate Office, K.R. Circle, Bangalore-01 Date: 23-11-2015
Encl:	CYS-117

Proceedings of the accident Review meeting held on 17.11.2015 at 11.30 AM in the Conference hall, Corporate Office, BESCOM, K. R. Circle, Bangalore.

Meeting Agenda:	Safety Protocol and Accident analysis
In the Chair:	Sri.Pankaj Kumar Pandey, Managing Director
Members Present:	
1. Sri. H. Nagesh	Director (Technical), BESCOM.
2. Sri. Hanumantharaju	Chief Engineer (El.), BRAZ, BESCOM.
3. Sri. Laxman Chawhan	Chief Engineer (El.), CTAZ, BESCOM.
4. Smt.G. Sheela	General Manager (El.), Q,S&S, BESCOM.
5. Sri. Siddabasappa	Additional Chief Electrical Inspector, GOK
6. All the Superintending Engineer (Ele) and Executive Engineers(Ele)	BRAZ and CTAZ, BESCOM
7. Sri. Gopalakrishna	DGM (Ele), Q,S&S, Corporate Office.
8. Sri. Siddalingappa	DGM (Ele), Q,S&S, Corporate Office.
9. Smt. Bhargavy V Y	AGM (El.), Q,S&S, BESCOM.
10. Sri. Ananda R Kulkarni	AGM (El.), Q,S&S, BESCOM.
11. Smt. D. Savitha	AGM (El.), Q,S&S, BESCOM.
12. Smt. Jyothi	AGM (El.), Q,S&S, BESCOM.

JS
24/11

AGM-4

Director(Technical), BESCOM reviewed the action taken on the proceedings of the meeting conducted on 17.10.2015 and the accident statistics of BESCOM for the month of October - 2015.

The following points were discussed:

• Fatal electrical accidents to non-departmental persons employed by Contract agency :

GM(Q,S&S) informed that the accidents have been reduced in October-15 month as compared to the last October-14. DT and MD instructed to take action in reducing the accidents and action to be initiated on agencies in case of fatal electrical accidents to non-departmental persons employed by Contract agency.

-Action: GM(Q,S&S), GM(CR)

• Iron poles:-

Instructed all SEE's / EE's to take up the work to replace the deteriorated iron poles and submit the photographs (before and after) for the rectified works to Q,S&S section.

-Action: GM (QS&S)/ SEE/EE O & M

• **Spacers :-**

Instructed to all SEE's / EE's to utilize the spacers efficiently wherever needed by awarding labour contract or by departmentally.

The progress for fixing of LT spacers shall be furnished to Q,S&S section every month along with the statistics.

-Action: GM (QS&S)/ SEE/EE O & M

• **LTD Boxes:**

Instructed to all SEE's / EE's to take up the works of fixing of LTD Boxes and send the compliance to Q,S&S section, if the LTDBs are not required then the same has to be diverted to Central stores and the diverted LTD Boxes will be utilized by BMAZ area.

-Action: CEE/GM (QS&S)/ SEE/EE O & M

• **HT/LT lines over the Govt. schools and DTCs in Govt. Schools / Aanganwadi Premises**

Instructed to collect the details for HT/LT line and DTCs from DDPIs and BEOs. Instructed all SEEs/EEs to get the details at the earliest and also to prepare estimates for the same and take up the works immediately after getting the necessary budget approval.

-Action: GM (QS&S)/ SEE/EE O & M



**(Pankaj Kumar Pandey)
Managing Director,
BESCOM.**

Copy to:

1. The Chief Electrical Inspector to Govt., No 32/1-2 Crescent Towers , 2nd Floor, Crescent Road, Bangalore-560001
2. The Chief General Manager (CA), BESCOM Corporate Office, Bangalore, for information.
3. The Chief Engineers (Elect.), BMAZ, BRAZ & CTAZ O & M Zones, BESCOM
4. The General Manager (CR), Corporate Office, BESCOM to please arrange to upload this proceedings in BESCOM website
5. All The Superintending Engineers (El.), C,O&M Circles, BESCOM.
6. The Deputy General Manager (El.)-2, Q&S, BESCOM Corporate office, for information.
7. All Executive Engineers (Ele.) C,O&M Divisions, BESCOM.
8. The Assistant General Manager (El.)-2 &3, Q&S, BESCOM Corporate office, for information.
9. PS to MD/DT/DF- to place before MD/DT/DF
10. Office Copy / M.F.